

Cheryl Frazier

From: Cheryl Frazier
Sent: Friday, December 09, 2011 8:37 AM
To: Cheryl Frazier
Subject: FW: <https://doc.acton-ma.gov/dsweb/View/Collection-4406>

From: Doug Halley
Sent: Thursday, December 08, 2011 11:09 AM
To: Cheryl Frazier; Frank Ramsbottom; Tom Tidman; Health Department; Planning Department; Engineering Department; Robert Craig
Subject: RE: <https://doc.acton-ma.gov/dsweb/View/Collection-4406>

The Health Department has reviewed the application for Site Plan Special Permit 07/16/11-433 and have the following comments:

1. The proposed subsurface sewage disposal system plan submitted with this application is not the same as the plan submitted to the Health Department for review and approval. Revisions of that plan have been made on July 19th and September 20th which have not been reviewed by the Health Department. The applicant should submit the appropriately revised plan to the Health Department for review.
 2. A Hazardous Materials Control Permit will be required for this site. It must be applied for prior to an occupancy permit being issued.
 3. No provisions have been made for storage of trash generated on site.
 4. This site is located adjacent to an existing 21E site. Based on this the Health Department requests that any 21E studies done for this property be given to the town for review.
-